



American Packing Industries (Philippines) Corporation

Km. 21 South Luzon Expressway, Samson Road, Brgy. Sucat, 1771 Muntinlupa City Philippines
Tel Nos.: (632) 807-6054; 807-6163; 807-6156; 807-6128
Fax No.: (632) 807-8662
E-mail: www.americanpackingindustries.com

Original Copy

SAMPLE TESTING REPORT

Attention : Engr. Maximino Plata
CMMP Planner

Project : Sample Testing for Caustic Soda Pipe Leak Repair

Location : Alaska, San Pedro, Laguna

Inspection Date: September 26, 2017


A. Description: Caustic Soda pipe

B. Scope of work and methodology:

- b.1. Proper surface preparation by means of manual sanding to achieved minimum surface profile for substrate of metal. Removal of dirt, grease, oil and corroded part of pipe.
- b.2. Application of UPS 105 EG at first coating at 250 microns. UPS 'Super Metal Rebuilding System' is a high performance multi purpose synthetic metal repair compound specifically developed for metal repairs requiring good mechanical strength combined with easy machining properties.
- b.3. Application of UPS 19 UPS 19007/9/11 Glass Tape is a high performance unique braided Glass Fibre Tape that, when used in conjunction with the UPS 19000 RH offers the ultimate in both Leak Sealing and Pipe Protection.
- b.4. Top coating using 105EG at 250 microns
- b.5. Curing time at least 24 hours. Full mechanical cured for 48 hours.

C. Completion date: September 27, 2017

D. Attached Photos:



Before




During



After

Sincerely yours,


Jay Nicdao Jr
TMG-Coats Div.
American Packing Industries

Accepted and Approved by:


Engr. Maximino Plata
Alaska Milk Corporation
CMMP Planner

Date:

12/13/2017

MAINTENANCE RELIABILITY ENGINEER